

**STANDARDS PRESENTATION  
TO  
CALIFORNIA OCCUPATIONAL SAFETY AND HEALTH STANDARDS BOARD**

Attachment No. 1

Page 1 of 1

PROPOSED STATE STANDARD,  
TITLE 8, DIVISION 1, CHAPTER 4

Amend Section 5605 to read:

§5605. Protection of Tanks in ~~Locations That May Be Flooded~~ Areas Subject to Flooding.

Where an underground or above ground storage tank installed on or after October 1, 2014 is located in an area that may be subjected to flooding as defined by the Federal Emergency Management Agency (FEMA), installation shall conform to be in accordance with the provisions of NFPA No. 30-1973 NFPA 30-2012, Chapter 21, Section 21.7.3, Chapter 22, Section 22.5.2.5, and Section 22.14, Chapter 23, Section 23.14, and Annex A.23.14.1, which are hereby incorporated by reference. Such tanks in areas subject to flooding as defined by FEMA, installed prior to October 1, 2014, shall conform to either the foregoing provisions of the NFPA 30-2012 or to the NFPA 30-1973, Appendix B, which also is hereby incorporated by reference.

NOTE: FEMA flood maps and flood zone definitions are found at <https://msc.fema.gov>

NOTE: Authority cited: Section 142.3, Labor Code. Reference: Section 142.3, Labor Code.