

**STANDARDS PRESENTATION
TO
CALIFORNIA OCCUPATIONAL SAFETY AND HEALTH STANDARDS BOARD**

PROPOSED STATE STANDARD,
TITLE 8, CHAPTER 4

Amend Section 4650(d) to read as follows:

§ 4650. Storage, Handling, and Use of Cylinders.

- (d) Oxygen cylinders ~~shall never be stored near highly combustible materials, especially oil and grease, or near any other substance likely to cause or accelerate fire.~~ in storage shall be separated from fuel gas cylinders or combustible materials (especially oil or grease) a minimum distance of 20 feet or by a non-combustible barrier at least 5 feet high, or a minimum of 18 inches (25 centimeters) above the tallest cylinder and having a fire-resistance rating of at least one hour.

NOTE: Authority cited: Section 142.3, Labor Code. Reference: Section 142.3, Labor Code.