

**STANDARDS PRESENTATION  
TO  
CALIFORNIA OCCUPATIONAL SAFETY AND HEALTH STANDARDS BOARD**

Attachment No. 1

Page 1 of 5

PROPOSED STATE STANDARD,  
TITLE 8, DIVISION 1, CHAPTER 4

Add new Section 5184 to read

~~§5184. Hazardous Mixtures. (Repealed)~~

§5184. Storage Battery Systems.

(a) Scope and Application. This section applies to stationary storage battery systems, used for standby power, emergency power, or uninterrupted power supplies.

(b) Definitions. For the purposes of this section and Section 5185, the following shall apply:

Battery System means a system which consists of three interconnected subsystems: a battery, a battery charger, and a collection of rectifiers, inverters, converters, and associated electrical equipment as required for a particular application.

Stationary Storage Battery means a group of electrochemical cells interconnected to supply a nominal voltage of DC power to a suitably connected electrical load, designed for service in a permanent location. After discharge, it may be restored to a fully charged condition by an electric current flowing in a direction opposite to the flow of current when the battery is discharged.

(c) Storage battery systems shall meet the applicable requirements of Section 5185 as well as the requirements of this section.

(d) Battery systems shall contain approved equipment, devices and/or procedures which preclude, detect and control failure.

(e) Safety caps shall be maintained in proper working order.

NOTE: Authority cited: Section 142.3, Labor Code. Reference: Section 142.3, Labor Code.

**STANDARDS PRESENTATION  
TO  
CALIFORNIA OCCUPATIONAL SAFETY AND HEALTH STANDARDS BOARD**

PROPOSED STATE STANDARD,  
TITLE 8, DIVISION 1, CHAPTER 4

Amend Section 5185 to read:

§5185. Changing and Charging Storage Batteries.

(a) In addition to the requirements below, the changing and charging of batteries shall comply with applicable requirements of Section 5184.

~~(a)~~ Battery charging installations shall be located in areas designated for that purpose. Employees assigned to work with storage batteries shall be qualified employees and shall be instructed in emergency procedures such as dealing with accidental acid spills.

~~(b) The area shall be adequately ventilated to prevent concentrations of flammable gases exceeding 20 percent of the lower explosive limit, and to prevent harmful concentration of mist from the electrolyte.~~

(c) Where storage batteries capable of venting flammable gas or corrosive mist are installed or charged, the space shall be ventilated by natural or mechanical means to prevent concentrations of flammable gases from exceeding 20% of the lower explosive limit of the gas, and harmful levels of mist from the electrolyte.

~~(d) Where corrosive liquids are regularly or frequently handled in open containers or drawn from reservoirs or pipelines, adequate~~ or can potentially be released, means shall be provided to neutralize or dispose of spills and overflows ~~promptly and safely.~~

~~(d) Carboy tilter, siphon, hand-operated bulb or hand-operated pump shall be provided and used for dispensing electrolyte or acid.~~

(e) When dispensing or sampling electrolyte, only devices specifically designed for such activities shall be used.

~~(e) Facilities shall be provided for protecting charging apparatus from damage by mobile equipment.~~

~~(f) Appropriate mechanical lifting and material handling devices or equipment shall be provided for handling batteries.~~

~~(g) Smoking shall be prohibited in the charging area.~~

~~(h) Precautions shall be taken to prevent open flames, sparks, or electric arcs in battery charging areas. When racks are used for support of batteries, they shall be made of materials~~

**STANDARDS PRESENTATION  
TO  
CALIFORNIA OCCUPATIONAL SAFETY AND HEALTH STANDARDS BOARD**

Attachment No. 1

Page 3 of 5

PROPOSED STATE STANDARD,  
TITLE 8, DIVISION 1, CHAPTER 4

~~nonconductive to spark generation or coated or covered to achieve this objective. Tools and other metallic objects shall be kept away from the top of uncovered batteries. Chargers shall be turned off when leads are being connected or disconnected.~~

(~~if~~) Electrolyte (acid or base, and distilled water) for battery cells shall be mixed in a well-ventilated room. Acid or base shall be poured gradually into the water while stirring. Water shall never be poured into concentrated (greater than 75 percent) acid solutions.

~~(j) Mobile equipment shall be properly positioned and brake applied before attempting to change or charge batteries.~~

~~(k) When charging batteries, the vent caps shall be kept firmly in place to avoid electrolyte spray. Care shall be taken to assure that vent caps are functioning. The battery compartment cover(s) shall be open to dissipate heat.~~

~~(l) Facilities for quick drenching or flushing of the eyes and body shall be provided unless the storage batteries are:~~

~~(1) equipped with explosion resistant or flame arrestor type vents; or~~

~~(2) located in a compartment or other location such as to preclude employee exposure.~~

~~EXCEPTIONS: Automotive servicing facilities and parts stores where:~~

~~1. A suitable neutralizing agent is available.~~

~~2. An adequate supply of clean water is readily available.~~

~~3. The transfer system is essentially a closed system and does not involve handling acid in open containers.~~

(~~mg~~) When taking specific gravity readings, the open end of the hydrometer shall be covered with an acid resistant material while moving it from battery to battery to avoid splashing or throwing the electrolyte.

(~~nh~~) Electrolyte shall only be placed in suitable containers and shall not be stirred with metal objects.

**STANDARDS PRESENTATION  
TO  
CALIFORNIA OCCUPATIONAL SAFETY AND HEALTH STANDARDS BOARD**

PROPOSED STATE STANDARD,  
TITLE 8, DIVISION 1, CHAPTER 4

(i) Facilities shall be provided for protecting charging apparatus from damage by mobile equipment. Mobile equipment shall be properly positioned and brake applied before attempting to change or charge batteries.

(j) Mechanical lifting and material handling devices or equipment shall be provided for handling batteries.

(k) Smoking shall be prohibited in the charging area.

(l) Precautions shall be taken to prevent static discharge, open flames, sparks, short circuits, or electric arcs in areas where batteries are charged. When racks are used for support of batteries, they shall be made of materials nonconductive to spark generation or coated or covered to achieve this objective. Tools and other metallic objects shall be kept away from the top of uncovered batteries. Chargers shall be turned off when leads are being connected or disconnected.

(m) When charging batteries, with vent caps, the vent caps shall be kept firmly in place to avoid electrolyte spray.-The battery compartment cover(s) shall be open to dissipate heat.

(n) Facilities for quick drenching or flushing of the eyes and body shall be provided in accordance with Section 5162 unless the storage batteries are:

(1) equipped with explosion resistant or flame arrestor type vents; or

(2) located in a compartment or other location such as to preclude employee exposure.

EXCEPTION to Subsection (n): Automotive servicing facilities and parts stores where:

1. A suitable neutralizing agent is available, and

2. An adequate supply of clean water is readily available, and

3. The transfer system is essentially a closed system and does not involve handling acid in open containers.

(o) When a jumper battery is connected to a battery in a vehicle, the ground lead shall connect to ground away from the vehicle's battery. Ignition, lights and accessories on the vehicle shall be turned off before connections are made.

(p) Vent caps shall be in place when batteries are being moved.

**STANDARDS PRESENTATION  
TO  
CALIFORNIA OCCUPATIONAL SAFETY AND HEALTH STANDARDS BOARD**

PROPOSED STATE STANDARD,  
TITLE 8, DIVISION 1, CHAPTER 4

EXCEPTIONS to Subsection (p): Portable equipment battery systems:

Batteries and battery charging equipment of less than 100 watt hours are exempt.

(q) Personal protective equipment shall be provided in accordance with Section 3380.

NOTE: Authority cited: Section 142.3, Labor Code. Reference: Section 142.3, Labor Code.