

**STANDARDS PRESENTATION
TO
CALIFORNIA OCCUPATIONAL SAFETY AND HEALTH STANDARDS BOARD**

PROPOSED STATE STANDARD,
TITLE 8, DIVISION 1, CHAPTER 4

Amend Section 6325 to read:

§6325. Fueling and Fueling Area.

(e) The helicopter and fuel supply system shall be securely bonded together ~~and grounded, with a driven rod attached to the rear of the fuel pump~~ before and during fueling operations to provide static electrical discharge.

NOTE: Authority cited: Section 142.3, Labor Code. Reference: Section 142.3, Labor Code.