

**STANDARDS PRESENTATION
TO
CALIFORNIA OCCUPATIONAL SAFETY AND HEALTH STANDARDS BOARD**

PROPOSED STATE STANDARD,
TITLE 8, DIVISION 1, CHAPTER 4

Amend Section 1742 to read:

§1742. Hose and Connections.

(d) The connection between fuel source and burner shall be with extra heavy steel pipe (Schedule 80), flexible metallic tubing or hose suitable for the service, and where exposed shall be protected against physical damage.

(e) When not in use, manifold and header hose connections shall be capped. As used in this subsection, “manifold” means a device used to connect the outlets of one or more gas cylinders to a central piping system, and “header” means a pipe or duct through which liquid or gas is conveyed and supplied to or received from multiple branches.

(f) When parallel sections of oxygen and fuel gas hose are taped together, not more than 4 inches out of 12 inches shall be covered by tape.

NOTE: Authority cited: Section 142.3, Labor Code. Reference: Section 142.3, Labor Code.