

TITLE 24  
CALIFORNIA ENERGY CODE

PART 6, SECTION 121, REQUIREMENTS FOR VENTILATION

TABLE NO. 1-F -- MINIMUM VENTILATION RATES

TYPE OF USE	CFM PER SQUARE FOOT OF CONDITIONED FLOOR AREA
Auto repair workshops	1.50
Barber shops	0.40
Bars, cocktail lounges and casinos	1.50
Beauty shops	0.40
Coin-operated dry cleaning	0.30
Commercial dry cleaning	0.45
High-rise residential	Per UBC, Section 1205
Hotel guest rooms (under 500ft <sup>2</sup> )	30 cfm/guest room
Retail stores	0.20
Smoking lounges	1.50
All Others	0.15

C-48, Attachment E (08/01/94)