

EXECUTIVE SUMMARY
OCCUPATIONAL SAFETY AND HEALTH
APPEALS BOARD

Summary of The Herrick Corp – Decision After Reconsideration

The work activity of removing a temporary floor hole covering in preparation for installation of steel decking which eliminated temporary opening in a steel framed building was steel erection activity covered by the fall protection requirements of 1710.

The Herrick Corp. 07-0495

March 26, 2012

1710