

**STANDARDS PRESENTATION
TO
CALIFORNIA OCCUPATIONAL SAFETY AND HEALTH STANDARDS BOARD**

Attachment No. 1

Page 1 of 1

PROPOSED STATE STANDARD,
TITLE 8, CHAPTER 4

Amend Section 3518(a) to read:

§ 3518. Air Compressors

- (a) Air compressor discharge lines having a block valve between the air receiver and compressor shall have a pressure relieving safety device installed in the line between the compressor and block valve. The pressure relieving safety device shall be set to open at a pressure not to exceed the rated working pressure of the cylinder. The relieving capacity of the pressure relieving safety device shall be such as to prevent a rise of pressure in the compressor cylinder of more than 10 percent above its maximum allowable working pressure, and the discharge shall be to a safe place.

EXCEPTION: Centrifugal (radial) compressor systems that are incapable by design of exceeding the maximum allowable working pressure of the system need not be equipped with a discharge line pressure relieving device.

Note: Authority cited: 142.3 Labor Code. Reference: 142.3, Labor Code.