STATE OF CALIFORNIA-OFFICE OF ADMINISTRATIVE LAW For use by Secretary of State only structions on NOTICE PUBLICATION/REGULATIONS SUBMISSION reverse):: 5TD. 400 (REV. 01-2013) NOTICE FILE NUMBER OAL FILE REGULATORY ACTION NUMBER EMERGENCY NUMBER: : NUMBERS Z-2019-0315-02 2019-1022-015 For use by Office of Administrative Law (OAL) only **ENDORSED - FILED** 2019 OCT 22 A 10: 20 in the office of the Secretary of State RECEIVED DATE **PUBLICATION DATE** of the State of California OFFICE OF DEC .05 2019 ADMINISTRATIVE LAW MAR 15 MAR 29'19 Office of Administrative Law REGULATIONS AGENCY FILE NUMBER (If any) AGENCY WITH RULEMAKING AUTHORITY Occupational Safety and Health Standards Board A. PUBLICATION OF NOTICE (Complete for publication in Notice Register) 1. SUBJECT OF NOTICE 2. REQUESTED PUBLICATION DATE LVESO and HVESO, see attached **LVESO 2300** March 29, 2019 Title 8 3. NOTICE TYPE
Notice re Proposed TELEPHONE NUMBER FAX NUMBER (Optional) 4. AGENCY CONTACT PERSON (916)-274-5743 Regulatory Action Lara Paskins, SSM I (916)-274-5721 NOTICE REGISTER NUMBER OAL USE ONLY B. SUBMISSION OF REGULATIONS (Complete when submitting regulations) Electric Power Generation, Transmission Previous Related Oal REGulatory action Number(s) 1a. SUBJECT OF REGULATION(S) and Distribution; Electrical Protective Equipment; Final Rule-Corrections 2. SPECIFY CALIFORNIA CODE OF REGULATIONS TITLE(S) AND SECTION(S) (Including title 26, if toxics related) ADOPT SECTION(S) AFFECTED (List all section number(s) individually. Attach additional sheet if needed.) 2305.2, and 2940.2 and Appendix A to Article 36 TITLE(S) 3. TYPE OF FILING Regular Rulemaking (Gov. Certificate of Compliance: The agency officer named Emergency Readopt (Gov. Changes Without Regulatory Code §11346) below certifies that this agency complled with the Code, §11346.1(h)) Effect (Cal. Code Regs., title Resubmittal of disapproved or provisions of Gov. Code §§11346.2-11347.3 either 1, §100) withdrawn nonemergency before the emergency regulation was adopted or Print Only File & Print filing (Gov. Code §§11349.3, within the time period required by statute. 11349.4) Resubmittal of disapproved or withdrawn Emergency (Gov. Code, emergency filing (Gov. Code, §11346.1) §11346.1(b)) 4. ALL BEGINNING AND ENDING DATES OF AVAILABILITY OF MODIFIED REGULATIONS AND/OR MATERIAL ADDED TO THE RULEMAKING FILE (Cal. Code Regs. title 1, \$44 and Gov. Code \$11347.1) 5. EFFECTIVE DATE OF CHANGES (Gov. Code, 59 11343.4, 11346.1(d); Cal. Code Regs., title 1, 9100) Effective January 1, April 1, July 1, or Effective Effective on filing with 5100 Changes Without October 1 (Gov. Code §11343.4(a)) Regulatory Effect other (Specify) Secretary of State 6. CHECK IF THESE REGULATIONS REQUIRE NOTICE TO, OR REVIEW, CONSULTATION, APPROVAL OR CONCURRENCE BY, ANOTHER AGENCY OR ENTITY Fair Political Practices Commission State Fire Marshal Department of Finance (Form STD. 399) (SAM §6660) Other (Specify) 7. CONTACT PERSON TELEPHONE NUMBER FAX NUMBER (Optional) E-MAIL ADDRESS (Optional) cshupe **C**dir.ca.gov <del>(916)-</del>274-5721 For use by Office of Administrative Law (OAL) only I certify that the attached copy of the regulation(s) is a true and correct copy of the regulation(s) identified on this form, that the information specified on this form is true and correct, and that I am the head of the agency taking this action, or a designee of the head of the agency, and am authorized to make this certification. DEC 05 2019 6-21-19

Christina Shupe, Executive Officer

Office of Administrative Law

Subject of Notice - Continued

Item 1 of 1 continued

<u>Low Voltage Electrical Safety Orders</u> Sections 2300 and 2305.2

<u>High Voltage Electrical Safety Orders</u> Sections 2940.2 and Appendix A to Article 36

### CALIFORNIA OCCUPATIONAL SAFETY AND HEALTH STANDARDS BOARD

#### TITLE 8, DIVISION 1, CHAPTER 4

Subchapter 5. Electrical Safety Orders Group 1. Low-Voltage Electrical Safety Orders Article 1. Definitions

Amend Section 2300 to read:

§2300. Scope Definitions.

- (a) Only definitions of terms peculiar to and essential to the proper use of this Safety Order are included. In general, only those terms used in two or more Articles are defined in Article 1. Other definitions are included in the Article in which they are used but may be referenced in Article 1.
- (b) Definitions.

\*\*\*\*

NOTE: Authority cited: Section 142.3, Labor Code. Reference: Section 142.3, Labor Code.

#### CALIFORNIA OCCUPATIONAL SAFETY AND HEALTH STANDARDS BOARD

#### TITLE 8, DIVISION 1, CHAPTER 4

Subchapter 5. Electrical Safety Orders Group 1. Low-Voltage Electrical Safety Orders Article 2. Administration

Amend Section 2305.2 to read:

§2305.2. Scope and Application.

(a) These Low-Voltage Electrical Safety Orders apply to all electrical installations and electrical equipment operating or intended to operate on systems of 600 volts, nominal, or less and to all work performed directly on or in proximity to such electrical installations, equipment or systems in all places of employment in the State of California as defined in Labor Code Section 6303.

\*\*\*\*

NOTE: Authority cited: Section 142.3, Labor Code. Reference: Section 142.3, Labor Code.

### CALIFORNIA OCCUPATIONAL SAFETY AND HEALTH STANDARDS BOARD

#### TITLE 8, DIVISION 1, CHAPTER 4

Subchapter 5. Electrical Safety Orders Group 2. High-Voltage Electrical Safety Orders Article 36. Work Procedures and Operating Procedures

Amend Section 2940.2 to read:

§2940.2. Minimum Approach Distances.

\*\*\*\*

- (d) Working Position.
- (1) When performing work with live line tools, minimum approach distances in accordance with subsection (a) shall be maintained. Conductor support tools, such as link sticks, strain carriers, and insulator cradles, shall be permitted to be used provided that the clear insulation is at least as long as the insulator string or the minimum approach distance specified in subsection (a).

| Table 2940.2-1 AC Live-Line   | e Work Minimum Approach Distance                               |
|---|--|
| The minimum approach distance (MAD; in meters) shall conform to the following equations.                          | 1  |
| For phase-to-phase system voltages of 60  | 1V, ,  |
| to 5 kV: 1  | X  |
| MAD = M + D, where  |  |
| D = 0.02  m   | D is the electrical component of the minimum approach distance |
| M = 0.31 m for voltages up to 750V and 0.61 m otherwise   | M is the inadvertent movement factor                           |
| For phase-to-phase system voltages of 5.1 kV to 72.5 kV: 1,-4   | ×  |
| MAD = M + AD, where   |  |
| M = 0.61  m   | M is the inadvertent movement factor                           |
| A = the applicable value from 2940.2-7  | A is the altitude correction factor                            |
| D = the value from 2940.2-2 corresponding to the voltage and exposure or the value of the electrical component of | D is the electrical component of the minimum approach distance |

### CALIFORNIA OCCUPATIONAL SAFETY AND HEALTH STANDARDS BOARD

| the minimum approusing the method p to this article  |                   |                                  | A  |  |                    |  |
|--|-------------------|----------------------------------|--|--|--------------------|--|
| For phase-to-phasthan 72.5 kV, non   |                   |                                  | ore  |  |                    |  |
| MAD = 0.3048(C +   |                   |                                  |  |  |                    |  |
| C = 0.01 for phase-to-ground exponent can demonstrate contactors the approach distance (0.01 for phase-to-phase expose can demonstrate that no insular gap and the no large conducting gap, or 0.011 otherwise |                   |                                  | trate consist on<br>stance (gap),<br>se exposures if to<br>no insulated too  | ance (gap),<br>exposures if the employer<br>insulated tool spans the |                    |  |
| $V_{L-G} =$  |                   |                                  | phase-to-ground rms v  | oltage, in kV  |                    |  |
| T =  |                   |                                  | maximum anticipated per-unit transient overvoltage; for phase-to-ground exposures, T equals T <sub>L-G</sub> , the maximum per-unit transient overvoltage, phase-to-ground, determined by the employer under subsection (a)(1)(A) of this section; for phase-to-phase exposures, T equals 1.35T <sub>L-G</sub> +0.45 |  |                    |  |
| A =  |                   |                                  | altitude correction fact   | tor from 2940.2  | 2-7                |  |
| M =  |                   |                                  | 0.31 m, the inadvertent movement factor  |  |                    |  |
| a =  |                   |                                  | saturation factor, as follows:   |  |                    |  |
| Phase-to-Ground  | Exposu            | re                               | $\times$   |  |                    |  |
| $V_{Peak} = T_{L-G}V_{L-G}\sqrt{2}$  | 635 kV<br>or less | 635.1 to 915 kV                  | V 915.1 to 1,050 kV More than 1,050 kV   |  |                    |  |
| <u> </u>   | 0                 | (V <sub>Peak</sub> -635)/140,000 | (V <sub>Peak</sub> -645)/135,000 (V <sub>Peak</sub> -675)/125,000  |  |                    |  |
| Phase-to-Ground  | Phase E           | xposure <sup>3</sup>             | $\times$   |  |                    |  |
| $V_{Peak}$ =(1.35 $T_{L-g}$ +0.45) $V_{L-g}$ $\sqrt{2}$  | 630 kV<br>or less | 630.1 to 848 kV                  | 848.1 to 1,131 kV  | 1,131.1 to<br>1,485 kV   | More than 1,485 kV |  |

#### CALIFORNIA OCCUPATIONAL SAFETY AND HEALTH STANDARDS BOARD

#### TITLE 8, DIVISION 1, CHAPTER 4

| A <u>a</u> | 0 | (V <sub>Peak</sub> -630)/155,000 | (V <sub>Peak</sub> -633.6)/152,207 | (V <sub>Peak</sub> -628)/ <u>153,846</u> | (V <sub>Peak</sub> - 350.5/<br>203,666 |
|------------|---|----------------------------------|------------------------------------|--|--|
|------------|---|----------------------------------|------------------------------------|--|--|

\*\*\*\*

\*\*\*\*

\*\*\*\*

NOTE: Authority cited: Section 142.3, Labor Code. Reference: Section 142.3, Labor Code.

<sup>&</sup>lt;sup>2</sup> Employers may use the minimum approach distances in Table 2940.2-4 except that the employer may not use the minimum approach distances in Table 2940.2-4 for phase-to-phase exposures if an insulated tool spans the gap or if any large conductive object is in the gap. If the worksite is at an elevation of more than 900 meters (3,000 feet), see footnote 1 to Table 2940.2-4. Employers may use the minimum approach distance in Table 14 through Table 21 Table 6 through Table 13 in Appendix A to this article, which calculated MAD for various values of T, provided the employer follows the notes to those tables.

<sup>&</sup>lt;sup>4</sup>Until October 1, 2018, employees may use the minimum approach distances in Table 6 in Appendix A of this Article.

### CALIFORNIA OCCUPATIONAL SAFETY AND HEALTH STANDARDS BOARD

#### TITLE 8, DIVISION 1, CHAPTER 4

Subchapter 5. Electrical Safety Orders Group 2. High-Voltage Electrical Safety Orders Article 36. Work Procedures and Operating Procedures

Amend Appendix A to read:

#### Appendix A

#### **WORKING ON EXPOSED ENERGIZED PARTS**

\*\*\*\*

V. Minimum Approach – Distance Tables

A. Legacy Tables. Employers may use the minimum approach distances in Table 6 through 13 until October 1, 2018.

| TABLE 6-MINIMUM APPROACH DISTANCES UNTIL |                 |                  |                 |                  |
|--|-----------------|------------------|-----------------|------------------|
| <del>OC</del>                            | FOBER 1, 2018   |                  |                 |                  |
| Voltage range phase to phase (kV)        | Phase-to-ground | exposure         | Phase-to-pha    | ase exposure     |
| voltage range phase to phase (k v)       | <del>m</del>    | fŧ               | m               | fŧ               |
| 0.05 to 1.0                              | Avoid Cor       | <del>ntact</del> | Avoid           | Contact          |
| <del>1.1 to 15.0</del>                   | 0.64            | <del>2.10</del>  | <del>0.66</del> | <del>2.20</del>  |
| 15.1 to 36.0                             | 0.72            | <del>2.30</del>  | 0.77            | <del>2.60</del>  |
| 36.1 to 46.0                             | 0.77            | 2.60             | 0.85            | <del>2.80</del>  |
| 46.1 to 72.5                             | 0.90            | 3.00             | 1.05            | <del>3.50</del>  |
| 72.6 to 121                              | 0.95            | 3.20             | 1.29            | 4.30             |
| 138 to 145                               | 1.09            | 3.60             | 1.50            | 4.90             |
| <del>161 to 169</del>                    | 1.22            | 4.00             | 1.71            | <del>5.70</del>  |
| <del>230 to 242</del>                    | 1.59            | 5.30             | <del>2.27</del> | <del>7.50</del>  |
| 345 to 362                               | 2.59            | 8.50             | 3.80            | 12.50            |
| <del>500 to 550</del>                    | 3.42            | 11.30            | 5.50            | 18.10            |
| <del>765 to 800</del>                    | 4.53            | 14.90            | <del>7.91</del> | <del>26.00</del> |

Note: The clear live-line tool distance must equal or exceed the values for the indicated voltage ranges.

### CALIFORNIA OCCUPATIONAL SAFETY AND HEALTH STANDARDS BOARD

### TITLE 8, DIVISION 1, CHAPTER 4

| TABLE 7-MINIMUM APPROACH DISTANCES UNTIL  OCTOBER 1, 2018,  72.6 TO 121.0 kV WITH OVERVOLTAGE FACTOR |               |                 |              |              |  |
|--|---------------|-----------------|--------------|--------------|--|
| Т (р. н. )   | Phase-to-grou | and exposure    | Phase-to-pha | ase exposure |  |
| <u>T (p.u.)</u>  | <u>m</u>      | <u>ft</u>       | <u>m</u>     | <u>ft</u>    |  |
| <u>2.0</u>   | <u>0.74</u>   | <u>2.42</u>     | <u>1.09</u>  | <u>3.58</u>  |  |
| <u>2.1</u>   | <u>0.76</u>   | <u>2.50</u>     | <u>1.09</u>  | <u>3.58</u>  |  |
| <u>2.2</u>   | <u>0.79</u>   | <del>2.58</del> | <u>1.12</u>  | <u>3.67</u>  |  |
| <u>2.3</u>   | <u>0.81</u>   | <del>2.67</del> | <u>1.14</u>  | <u>3.75</u>  |  |
| <u>2.4</u>   | <u>0.84</u>   | <u>2.75</u>     | <u>1.17</u>  | <u>3.83</u>  |  |
| <u>2.5.</u>  | <u>0.84</u>   | <u>2.75</u>     | <u>1.19</u>  | <u>3.92</u>  |  |
| <u>2.6</u>   | <u>0.86</u>   | <u>2.83</u>     | <u>1.22</u>  | <u>4.00</u>  |  |
| <u>2.7</u>   | <u>0.89</u>   | <del>2.92</del> | <u>1.24</u>  | <u>4.08</u>  |  |
| <u>2.8</u>   | <u>0.91</u>   | <u>3.00</u>     | <u>1.24</u>  | <u>4.08</u>  |  |
| <u>2.9</u>   | <u>0.94</u>   | <u>3.08</u>     | <u>1.27</u>  | <u>4.17</u>  |  |
| <u>3.0</u>   | <u>0.97</u>   | <u>3.17</u>     | <u>1.30</u>  | <u>4.25</u>  |  |

Note 1: The employer may apply the distance specified in this table only where the employer determines the maximum anticipated per-unit transient overvoltage by engineering analysis. (Table 6 applies otherwise.)

Note 2: The distances specified in this table are the air, bare-hand, and live-line tool distances.

| TABLE 8-MINIMUM APPROACH DISTANCES UNTIL OCTOBER 1, 2018,<br>121.1 TO 145.0 kV WITH OVERVOLTAGE FACTOR |                  |                 |                 |                          |  |  |
|--|------------------|-----------------|-----------------|--------------------------|--|--|
| Т (р. и.)  | Phase-to-grou    | und exposure    | Phase-to-ground | Phase-to-ground exposure |  |  |
| T (p.u.)   | m                | ft              | m               | fŧ                       |  |  |
| 2.0  | <del>0.84</del>  | 2.75            | 1.24            | 4.08                     |  |  |
| <del>2.1</del>   | <del>0.86</del>  | 2.83            | <del>1.27</del> | 4.17                     |  |  |
| <del>2.2</del>   | <del>0.89</del>  | <del>2.92</del> | 1.30            | 4.25                     |  |  |
| <del>2.3</del>   | <del>0.91</del>  | 3.00            | 1.32            | 4.33                     |  |  |
| 2.4  | <del>0.9</del> 4 | 3.08            | 1.35            | 4.42                     |  |  |
| <del>2.5</del>   | <del>0.97</del>  | 3.17            | 1.37            | 4.50                     |  |  |
| 2.6  | 0.99             | 3.25            | 1.40            | 4.58                     |  |  |
| 2.7  | 1.02             | 3.33            | 1.42            | 4.67                     |  |  |
| 2.8  | 1.04             | 3.42            | 1.45            | 4.75                     |  |  |

#### CALIFORNIA OCCUPATIONAL SAFETY AND HEALTH STANDARDS BOARD

#### TITLE 8, DIVISION 1, CHAPTER 4

| 2.9 | 1.07 | 3.50            | 1 4'/ | 4.83 |
|-----|------|-----------------|-------|------|
| 3.0 | 1.09 | <del>3.58</del> | 1 11  | 4.92 |

Note 1: The employer may apply the distance specified in this table only where the employer determines the maximum anticipated per-unit transient overvoltage by engineering analysis. (Table 6 applies otherwise.)

Note 2: The distances specified in this table are the air, bare-hand, and live-line tool distances.

| TABLE 9-MINIMUM APPROACH DISTANCES UNTIL<br>OCTOBER 1, 2018,<br>145.1 TO 169.0 kV WITH OVERVOLTAGE FACTOR |                 |                 |                 |                   |  |
|---|-----------------|-----------------|-----------------|-------------------|--|
|   | Phase-to-g      | round           | Phase-to        | <del>-phase</del> |  |
| <del>T (p.u.)</del>   | exposu          | <del>rre</del>  | expos           | <del>sure</del>   |  |
|   | m               | fŧ              | m               | fŧ                |  |
| 2.0   | <del>0.91</del> | 3.00            | <del>1.42</del> | <del>4.67</del>   |  |
| <del>2.1</del>  | <del>0.97</del> | 3.17            | <del>1.45</del> | 4.75              |  |
| 2.2   | 0.99            | 3.25            | 1.47            | 4.83              |  |
| 2.3   | 1.02            | 3.33            | 1.50            | 4.92              |  |
| 2.4   | 1.04            | 3.42            | 1.52            | 5.00              |  |
| 2.5   | 1.07            | 3.50            | 1.57            | 5.17              |  |
| 2.6   | 1.12            | <del>3.67</del> | 1.60            | 5.25              |  |
| <del>2.7</del>  | 1.14            | 3.75            | 1.63            | 5.33              |  |
| 2.8   | 1.17            | 3.83            | 1.65            | <del>5.42</del>   |  |
| <del>2.9</del>  | 1.19            | 3.92            | 1.68            | <del>5.50</del>   |  |
| 3.0   | <del>1.22</del> | 4.00            | 1.73            | <del>5.67</del>   |  |

Note 1: The employer may apply the distance specified in this table only where the employer determines the maximum anticipated per-unit transient overvoltage by engineering analysis. (Table 6 applies otherwise.)

Note 2: The distances specified in this table are the air, bare-hand, and live-line tool distances.

### TITLE 8, DIVISION 1, CHAPTER 4

| TABLE 10-MINIMUM APPROACH DISTANCES UNTIL OCTOBER 1, 2018,<br>169.1 TO 242.0 kV WITH OVERVOLTAGE FACTOR |          |                 |                          |      |  |
|---|----------|-----------------|--------------------------|------|--|
| T (p.u.)  | Phase-to | -ground         | Phase-to-ground exposure |      |  |
| 1 (2.5.)  | m        | ft              | m                        | ft   |  |
| 2.0   | 1.17     | 3.83            | 1.85                     | 6.08 |  |
| 2.1   | 1.22     | 4.00            | <del>1.91</del>          | 6.25 |  |
| 2.2<br>2.3  | 1.24     | 4.08            | <del>1.93</del>          | 6.33 |  |
| 2.3   | 1.30     | 4.25            | <del>1.98</del>          | 6.50 |  |
| 2.4   | 1.35     | 4.42            | 2.01                     | 6.58 |  |
| 2.4<br>2.5<br>2.6   | 1.37     | 4.50            | 2.06                     | 6.75 |  |
| 2.6   | 1.42     | 4.67            | 2.11                     | 6.92 |  |
| 2.7   | 1.47     | 4.83            | 2.13                     | 7.00 |  |
| 2.8   | 1.50     | 4.92            | 2.18                     | 7.17 |  |
| <del>2.9</del>  | 1.55     | <del>5.08</del> | <del>2.24</del>          | 7.33 |  |
| 3.0   | 1.60     | <del>5.25</del> | <del>2.29</del>          | 7.50 |  |

Note 1: The employer may apply the distance specified in this table only where the employer determines the maximum anticipated per-unit transient overvoltage by engineering analysis. (Table 6 applies otherwise.)

Note 2: The distances specified in this table are the air, bare-hand, and live-line tool distances.

| TABLE 11-MINIMUM APPROACH DISTANCES UNTIL OCTOBER 1, 2018,<br>242.1 TO 362.0 kV WITH OVERVOLTAGE FACTOR |                 |                 |                 |                             |  |
|---|-----------------|-----------------|-----------------|-----------------------------|--|
| T (p.u.)  | Phase to gr     | ound exposure   |                 | Phase-to-ground<br>exposure |  |
| <u> </u>  | m               | ft              | m               | fŧ                          |  |
| 2.0   | 1.60            | <del>5.25</del> | <del>2.62</del> | <del>8.58</del>             |  |
| 2.1   | 1.65            | 5.42            | <del>2.69</del> | 8.83                        |  |
| 2.2   | 1.75            | 5.75            | <del>2.79</del> | 9.17                        |  |
| 2.3   | 1.85            | 6.08            | <del>2.90</del> | <del>9.50</del>             |  |
| 2.4   | 1.93            | 6.33            | 3.02            | 9.92                        |  |
| 2.5   | 2.03            | 6.67            | 3.15            | 10.33                       |  |
| 2.6   | <del>2.16</del> | <del>7.08</del> | 3.28            | <del>10.75</del>            |  |
| 2.7   | 2.26            | <del>7.42</del> | <del>3.40</del> | <del>11.17</del>            |  |
| 2.8   | 2.36            | 7.75            | 3.53            | 11.58                       |  |

#### CALIFORNIA OCCUPATIONAL SAFETY AND HEALTH STANDARDS BOARD

#### TITLE 8, DIVISION 1, CHAPTER 4

| 2.9 | <del>2.49</del> | 8.17            | <del>3.68</del> | 12.08            |
|-----|-----------------|-----------------|-----------------|------------------|
| 3.0 | <del>2.59</del> | <del>8.50</del> | <del>3.81</del> | <del>12.50</del> |

Note 1: The employer may apply the distance specified in this table only where the employer determines the maximum anticipated per-unit transient overvoltage by engineering analysis. (Table 6 applies otherwise.)

Note 2: The distances specified in this table are the air, bare-hand, and live-line tool distances.

| TABLE 12-MINIMUM APPROACH DISTANCES UNTIL OCTOBER 1, 2018,<br>362.1 TO 552.0 kV WITH OVERVOLTAGE FACTOR |                 |                 |                 |                  |  |
|---|-----------------|-----------------|-----------------|------------------|--|
| T (** ** )  | Phase-to-gr     | round exposure  | Phase-to-g      | round exposure   |  |
| <del>T (p.u.)</del>   | m               | ft              | m               | ft               |  |
| 1.5   | 1.83            | 6.00            | 2.24            | 7.33             |  |
| 1.6   | 1.98            | 6.50            | <del>2.67</del> | <del>8.75</del>  |  |
| 1.7   | 2.13            | 7.00            | 3.10            | <del>10.17</del> |  |
| 1.8   | 2.31            | <del>7.58</del> | 3.53            | 11.58            |  |
| <del>1.9</del>  | <del>2.46</del> | 8.08            | 4.01            | <del>13.17</del> |  |
| 2.0   | <del>2.67</del> | 8.75            | 4.52            | 14.83            |  |
| 2.1   | 2.84            | 9.33            | 4.75            | 15.58            |  |
| 2.2   | 3.02            | <del>9.92</del> | 4.98            | <del>16.33</del> |  |
| 2.3   | 3.20            | 10.50           | 5.23            | <del>17.17</del> |  |
| 2.4   | 3.43            | 11.25           | <del>5.51</del> | <del>18.08</del> |  |

Note 1: The employer may apply the distance specified in this table only where the employer determines the maximum anticipated per unit transient overvoltage by engineering analysis. (Table 6 applies otherwise.)

Note 2: The distances specified in this table are the air, bare-hand, and live-line tool distances.

| TABLE 13-MINIMUM APPROACH DISTANCES UNTIL OCTOBER 1, 2018,<br>552.1 TO 800.0 kV WITH OVERVOLTAGE FACTOR |                 |                  |                 |                  |  |  |
|---|-----------------|------------------|-----------------|------------------|--|--|
| Phase to ground exposure Phase to ground exposure   |                 |                  |                 |                  |  |  |
| <del>1 (p.u.)</del>   | m               | fŧ               | m               | ft               |  |  |
| 1.5   | <del>2.95</del> | <del>9.67</del>  | <del>3.68</del> | <del>12.08</del> |  |  |
| 1.6   | 3.25            | 10.67            | 4.42            | <del>14.50</del> |  |  |
| 1.7   | <del>3.56</del> | <del>11.67</del> | <del>5.23</del> | <del>17.17</del> |  |  |

### CALIFORNIA OCCUPATIONAL SAFETY AND HEALTH STANDARDS BOARD

#### TITLE 8, DIVISION 1, CHAPTER 4

| 1.8 | <del>3.86</del> | 12.67            | 6.07            | <del>19.92</del> |
|-----|-----------------|------------------|-----------------|------------------|
| 1.9 | <del>4.19</del> | <del>13.75</del> | <del>6.99</del> | <del>22.92</del> |
| 2.0 | 4.55            | 14.92            | <del>7.92</del> | 26.00            |

Note 1: The employer may apply the distance specified in this table only where the employer determines the maximum anticipated per-unit transient overvoltage by engineering analysis. (Table 6 applies otherwise.)

Note 2: The distances specified in this table are the air, bare-hand, and live-line tool distances.

B. Alternative minimum approach distances. Employers may use the minimum approach distances in Table 146 through Table 2113 provided that the employer follows the notes to those tables.

| MINIMUM APPRO  | ACH DISTAN                                      | NCES-72.6 TO 121   | .0 KV   |
|----------------|---|--|---|
| Phase-to-groun | nd exposure                                     | Phase-to-groundp   | hase exposure   |
| m              | ft  | m  | ft  |
| 0.67           | 2.2   | 0.84   | 2.8   |
| 0.69           | 2.3   | 0.87   | 2.9   |
| 0.71           | 2.3   | 0.90   | 3.0   |
| 0.74           | 2.4   | 0.93   | 3.1   |
| 0.76           | 2.5   | 0.96   | 3.1   |
| 0.78           | 2.6   | 0.99   | 3.2   |
| 0.81           | 2.7   | 1.01   | 3.3   |
| 0.83           | 2.7   | 1.04   | 3.4   |
|                | Phase-to-ground m 0.67 0.69 0.71 0.74 0.76 0.78 | Phase-to-ground exposure           m         ft           0.67         2.2           0.69         2.3           0.71         2.3           0.74         2.4           0.76         2.5           0.78         2.6           0.81         2.7 | m ft m  0.67 2.2 0.84  0.69 2.3 0.87  0.71 2.3 0.90  0.74 2.4 0.93  0.76 2.5 0.96  0.78 2.6 0.99  0.81 2.7 1.01 |

| 2.3 | 0.85 | 2.8 | 1.07 | 3.5 |
|-----|------|-----|------|-----|
| 2.4 | 0.88 | 2.9 | 1.10 | 3.6 |
| 2.5 | 0.90 | 3.0 | 1.13 | 3.7 |
| 2.6 | 0.92 | 3.0 | 1.16 | 3.8 |
| 2.7 | 0.95 | 3.1 | 1.19 | 3.9 |
| 2.8 | 0.97 | 3.2 | 1.22 | 4.0 |
| 2.9 | 0.99 | 3.2 | 1.24 | 4.1 |
| 3.0 | 1.02 | 3.3 | 1.27 | 4.2 |
| 3.1 | 1.04 | 3.4 | 1.30 | 4.3 |
| 3.2 | 1.06 | 3.5 | 1.33 | 4.4 |
| 3.3 | 1.09 | 3.6 | 1.36 | 4.5 |
| 3.4 | 1.11 | 3.6 | 1.39 | 4.6 |
| 3.5 | 1.13 | 3.7 | 1.42 | 4.7 |

| TABL | TABLE <del>15</del> 7-AC MINIMUM APPROACH DISTANCES-121.1 TO 145.0 KV |                          |     |                                      |     |
|------|---|--------------------------|-----|--------------------------------------|-----|
|      | T (p.u.)  | Phase-to-ground exposure |     | Phase-to-<br>groundphase<br>exposure |     |
|      |   | m                        | ft  | m                                    | ft  |
| 1.5  |   | 0.74                     | 2.4 | 0.95                                 | 3.1 |
| 1.6  |   | 0.76                     | 2.5 | 0.98                                 | 3.2 |
| 1.7  |   | 0.79                     | 2.6 | 1.02                                 | 3.3 |
| 1.8  |   | 0.82                     | 2.7 | 1.05                                 | 3.4 |
| 1.9  |   | 0.85                     | 2.8 | 1.08                                 | 3.5 |
| 2.0  |   | 0.88                     | 2.9 | 1.12                                 | 3.7 |
| 2.1  |   | 0.90                     | 3.0 | 1.15                                 | 3.8 |
| 2.2  |   | 0.93                     | 3.1 | 1.19                                 | 3.9 |
| 2.3  |   | 0.96                     | 3.1 | 1.22                                 | 4.0 |
| 2.4  |   | 0.99                     | 3.2 | 1.26                                 | 4.1 |
| 2.5  |   | 1.02                     | 3.3 | 1.29                                 | 4.2 |
| 2.6  |   | 1.04                     | 3.4 | 1.33                                 | 4.4 |
| 2.7  |   | 1.07                     | 3.5 | 1.36                                 | 4.5 |
|      |   |                          |     |                                      |     |

| 2.8 | 1.10 | 3.6 | 1.39 | 4.6 |
|-----|------|-----|------|-----|
| 2.9 | 1.13 | 3.7 | 1.43 | 4.7 |
| 3.0 | 1.16 | 3.8 | 1.46 | 4.8 |
| 3.1 | 1.19 | 3.9 | 1.50 | 4.9 |
| 3.2 | 1.21 | 4.0 | 1.53 | 5.0 |
| 3.3 | 1.24 | 4.1 | 1.57 | 5.2 |
| 3.4 | 1.27 | 4.2 | 1.60 | 5.2 |
| 3.5 | 1.30 | 4.3 | 1.64 | 5.4 |
|     |      |     |      |     |

| TABLE 168-AC MINIMUM APPROACH DISTANCES-145.1 TO 169.0 KV |                 |          |                               |     |  |
|---|-----------------|----------|-------------------------------|-----|--|
| T (p.u.)  | Phase-to-ground | exposure | Phase-to-groundphase exposure |     |  |
| 1 (p.u.)  | m               | ft       | m                             | ft  |  |
| 1.5   | 0.81            | 2.7      | 1.05                          | 3.4 |  |
| 1.6   | 0.84            | 2.8      | 1.09                          | 3.6 |  |
| 1.7   | 0.87            | 2.9      | 1.13                          | 3.7 |  |
| 1.8   | 0.90            | 3.0      | 1.17                          | 3.8 |  |
| 1.9   | 0.94            | 3.1      | 1.21                          | 4.0 |  |
| 2.0   | 0.97            | 3.2      | 1.25                          | 4.1 |  |

| 1.00 | 3.3  | 1.29   | 4.2   |
|------|--|--|---|
| 1.03 | 3.4  | 1.33   | 4.4   |
| 1.07 | 3.5  | 1.37   | 4.5   |
| 1.10 | 3.6  | 1.41   | 4.6   |
| 1.13 | 3.7  | 1.45   | 4.8   |
| 1.17 | 3.8  | 1.49   | 4.9   |
| 1.20 | 3.9  | 1.53   | 5.0   |
| 1.23 | 4.0  | 1.57   | 5.2   |
| 1.26 | 4.1  | 1.61   | 5.3   |
| 1.30 | 4.3  | 1.65   | 5.4   |
| 1.33 | 4.4  | 1.70   | 5.6   |
| 1.36 | 4.5  | 1.76   | 5.8   |
| 1.39 | 4.6  | 1.82   | 6.0   |
| 1.43 | 4.7  | 1.88   | 6.2   |
| 1.46 | 4.8  | 1.94   | 6.4   |
|      | 1.03 1.07 1.10 1.13 1.17 1.20 1.23 1.26 1.30 1.33 1.36 1.39 1.43 | 1.03     3.4       1.07     3.5       1.10     3.6       1.13     3.7       1.17     3.8       1.20     3.9       1.23     4.0       1.26     4.1       1.30     4.3       1.33     4.4       1.36     4.5       1.39     4.6       1.43     4.7 | 1.03       3.4       1.33         1.07       3.5       1.37         1.10       3.6       1.41         1.13       3.7       1.45         1.17       3.8       1.49         1.20       3.9       1.53         1.23       4.0       1.57         1.26       4.1       1.61         1.30       4.3       1.65         1.33       4.4       1.70         1.36       4.5       1.76         1.39       4.6       1.82         1.43       4.7       1.88 |

| TABLE | TABLE <del>17</del> <u>9</u> -AC MINIMUM APPROACH DISTANCES-169.1 TO 242.0 KV |      |                          |      |     |
|-------|---|------|--------------------------|------|-----|
|       | T (p.u.)  |      | Phase-to-ground exposure |      |     |
|       |   | m    | ft                       | m    | ft  |
| 1.5   |   | 1.02 | 3.3                      | 1.37 | 4.5 |
| 1.6   |   | 1.06 | 3.5                      | 1.43 | 4.7 |
| 1.7   |   | 1.11 | 3.6                      | 1.48 | 4.9 |
| 1.8   |   | 1.16 | 3.8                      | 1.54 | 5.1 |
| 1.9   |   | 1.21 | 4.0                      | 1.60 | 5.2 |
| 2.0   | _   | 1.25 | 4.1                      | 1.66 | 5.4 |
| 2.1   | _   | 1.30 | 4.3                      | 1.73 | 5.7 |
| 2.2   |   | 1.35 | 4.4                      | 1.81 | 5.9 |
| 2.3   |   | 1.39 | 4.6                      | 1.90 | 6.2 |
| 2.4   | _   | 1.44 | 4.7                      | 1.99 | 6.5 |
| 2.5   | _   | 1.49 | 4.9                      | 2.08 | 6.8 |
| 2.6   |   | 1.53 | 5.0                      | 2.17 | 7.1 |
| 2.7   |   | 1.58 | 5.2                      | 2.26 | 7.4 |
| 2.8   |   | 1.63 | 5.3                      | 2.36 | 7.7 |

| 1.67 | 5.5                          | 2.45   | 8.0   |
|------|------------------------------|--|---|
| 1.72 | 5.6                          | 2.55   | 8.4   |
| 1.77 | 5.8                          | 2.65   | 8.7   |
| 1.81 | 5.9                          | 2.76   | 9.1   |
| 1.88 | 6.2                          | 2.86   | 9.4   |
| 1.95 | 6.4                          | 2.97   | 9.7   |
| 2.01 | 6.6                          | 3.08   | 10.1  |
|      | 1.72<br>1.77<br>1.81<br>1.88 | 1.72 5.6<br>1.77 5.8<br>1.81 5.9<br>1.88 6.2<br>1.95 6.4 | 1.72     5.6     2.55       1.77     5.8     2.65       1.81     5.9     2.76       1.88     6.2     2.86       1.95     6.4     2.97 |

| TABLE <u>4810</u> -AC MINIMUM APPROACH DISTANCES-242.1 TO 362.0 KV |                |            |                               |     |  |
|--|----------------|------------|-------------------------------|-----|--|
| T (p.u.)   | Phase-to-groun | d exposure | Phase-to-groundphase exposure |     |  |
| <b>Q</b> /   | m              | ft         | m                             | ft  |  |
| 1.5  | 1.37           | 4.5        | 1.99                          | 6.5 |  |
| 1.6  | 1.44           | 4.7        | 2.13                          | 7.0 |  |
| 1.7  | 1.51           | 5.0        | 2.27                          | 7.4 |  |
| 1.8  | 1.58           | 5.2        | 2.41                          | 7.9 |  |
| 1.9  | 1.65           | 5.4        | 2.56                          | 8.4 |  |
| 2.0  | 1.72           | 5.6        | 2.71                          | 8.9 |  |
| 2.1  | 1.79           | 5.9        | 2.87                          | 9.4 |  |

| 1.87 | 6.1   | 3.03  | 9.9   |
|------|---|---|---|
| 1.97 | 6.5   | 3.20  | 10.5  |
| 2.08 | 6.8   | 3.37  | 11.1  |
| 2.19 | 7.2   | 3.55  | 11.6  |
| 2.29 | 7.5   | 3.73  | 12.2  |
| 2.41 | 7.9   | 3.91  | 12.8  |
| 2.52 | 8.3   | 4.10  | 13.5  |
| 2.64 | 8.7   | 4.29  | 14.1  |
| 2.76 | 9.1   | 4.49  | 14.7  |
| 2.88 | 9.4   | 4.69  | 15.4  |
| 3.01 | 9.9   | 4.90  | 16.1  |
| 3.14 | 10.3  | 5.11  | 16.8  |
| 3.27 | 10.7  | 5.32  | 17.5  |
| 3.41 | 11.2  | 5.52  | 18.1  |
|      | 1.97 2.08 2.19 2.29 2.41 2.52 2.64 2.76 2.88 3.01 3.14 3.27 | 1.97     6.5       2.08     6.8       2.19     7.2       2.29     7.5       2.41     7.9       2.52     8.3       2.64     8.7       2.76     9.1       2.88     9.4       3.01     9.9       3.14     10.3       3.27     10.7 | 1.97     6.5     3.20       2.08     6.8     3.37       2.19     7.2     3.55       2.29     7.5     3.73       2.41     7.9     3.91       2.52     8.3     4.10       2.64     8.7     4.29       2.76     9.1     4.49       2.88     9.4     4.69       3.01     9.9     4.90       3.14     10.3     5.11       3.27     10.7     5.32 |

| T (p.u.) |      | Phase-to-ground exposure |      | Phase-to-groundphase exposure |  |
|----------|------|--------------------------|------|-------------------------------|--|
|          | m    | ft                       | m    | ft                            |  |
| 1.5      | 1.53 | 5.0                      | 2.40 | 7.9                           |  |
| 1.6      | 1.62 | 5.3                      | 2.58 | 8.5                           |  |
| 1.7      | 1.70 | 5.6                      | 2.75 | 9.0                           |  |
| 1.8      | 1.78 | 5.8                      | 2.94 | 9.6                           |  |
| 1.9      | 1.88 | 6.2                      | 3.13 | 10.3                          |  |
| 2.0      | 1.99 | 6.5                      | 3.33 | 10.9                          |  |
| 2.1      | 2.12 | 7.0                      | 3.53 | 11.6                          |  |
| 2.2      | 2.24 | 7.3                      | 3.74 | 12.3                          |  |
| 2.3      | 2.37 | 7.8                      | 3.95 | 13.0                          |  |
| 2.4      | 2.50 | 8.2                      | 4.17 | 13.7                          |  |
| 2.5      | 2.64 | 8.7                      | 4.40 | 14.4                          |  |
| 2.6      | 2.78 | 9.1                      | 4.63 | 15.2                          |  |
| 2.7      | 2.93 | 9.6                      | 4.87 | 16.0                          |  |
| 2.8      | 3.07 | 10.1                     | 5.11 | 16.8                          |  |

| 2.9 | 3.23 | 10.6 | 5.36 | 17.6 |
|-----|------|------|------|------|
| 3.0 | 3.38 | 11.1 | 5.59 | 18.3 |
| 3.1 | 3.55 | 11.6 | 5.82 | 19.1 |
| 3.2 | 3.72 | 12.2 | 6.07 | 19.9 |
| 3.3 | 3.89 | 12.8 | 6.31 | 20.7 |
| 3.4 | 4.07 | 13.4 | 6.56 | 21.5 |
| 3.5 | 4.25 | 13.9 | 6.81 | 22.3 |

| T (p.u.) | Phase-to-ground exposure |     | Phase-to-groundphase exposure |      |
|----------|--------------------------|-----|-------------------------------|------|
|          | m                        | ft  | m                             | ft   |
| 1.5      | 1.95                     | 6.4 | 3.46                          | 11.4 |
| 1.6      | 2.11                     | 6.9 | 3.73                          | 12.2 |
| 1.7      | 2.28                     | 7.5 | 4.02                          | 13.2 |
| 1.8      | 2.45                     | 8.0 | 4.31                          | 14.1 |
| 1.9      | 2.62                     | 8.6 | 4.61                          | 15.1 |
| 2.0      | 2.81                     | 9.2 | 4.92                          | 16.1 |
| 2.1      | 3.00                     | 9.8 | 5.25                          | 17.2 |

| 2.2 | 3.20 | 10.5 | 5.55 | 18.2 |
|-----|------|------|------|------|
| 2.3 | 3.40 | 11.2 | 5.86 | 19.2 |
| 2.4 | 3.62 | 11.9 | 6.18 | 20.3 |
| 2.5 | 3.84 | 12.6 | 6.50 | 21.3 |
| 2.6 | 4.07 | 13.4 | 6.83 | 22.4 |
| 2.7 | 4.31 | 14.1 | 7.18 | 23.6 |
| 2.8 | 4.56 | 15.0 | 7.52 | 24.7 |
| 2.9 | 4.81 | 15.8 | 7.88 | 25.9 |
| 3.0 | 5.07 | 16.6 | 8.24 | 27.0 |

| TABLE 21 <u>13</u> -A | C MINIMUM APF | PROACH DIST              | ANCES-550.1 TO 8 | 600.0 KV                      |  |  |
|-----------------------|---------------|--------------------------|------------------|-------------------------------|--|--|
| T (p.u.)              | Phase-to-grou | Phase-to-ground exposure |                  | Phase-to-groundphase exposure |  |  |
|                       | m             | ft                       | m                | ft                            |  |  |
| 1.5                   | 3.16          | 10.4                     | 5.97             | 19.6                          |  |  |
| 1.6                   | 3.46          | 11.4                     | 6.43             | 21.1                          |  |  |
| 1.7                   | 3.78          | 12.4                     | 6.92             | 22.7                          |  |  |
| 1.8                   | 4.12          | 13.5                     | 7.42             | 24.3                          |  |  |
| 1.9                   | 4.47          | 14.7                     | 7.93             | 26.0                          |  |  |

### CALIFORNIA OCCUPATIONAL SAFETY AND HEALTH STANDARDS BOARD

### TITLE 8, DIVISION 1, CHAPTER 4

| 4.83 | 15.8                         | 8.47   | 27.8  |
|------|------------------------------|--|---|
| 5.21 | 17.1                         | 9.02   | 29.6  |
| 5.61 | 18.4                         | 9.58   | 31.4  |
| 6.02 | 19.8                         | 10.16  | 33.3  |
| 6.44 | 21.1                         | 10.76  | 35.3  |
| 6.88 | 22.6                         | 11.38  | 37.3  |
|      | 5.21<br>5.61<br>6.02<br>6.44 | 5.21 17.1<br>5.61 18.4<br>6.02 19.8<br>6.44 21.1 | 5.21     17.1     9.02       5.61     18.4     9.58       6.02     19.8     10.16       6.44     21.1     10.76 |

Notes to Table 146 through Table 2113:

\*\*\*\*

NOTE: Authority cited: Section 142.3, Labor Code. Reference: Section 142.3, Labor Code.