

STANDARDS PRESENTATION
TO
CALIFORNIA OCCUPATIONAL SAFETY AND HEALTH STANDARDS BOARD

TITLE 8, DIVISION 1, CHAPTER 4

Subchapter 4. Construction Safety Orders
Article 18. Access and Egress

Amend Section 1630(a) as follows:

(a) In addition to the stairways required in Section 1629, a construction passenger elevator for hoisting workers shall be installed and in operation on or in any building, or structure, designed to be 60 feet or more in height above or 48 feet in depth below ground level when completed. The elevator shall be installed and operational when the building or structure reaches 36 feet in height. The building or structure height shall be determined by measuring from ground level to the highest structural level including the parapet walls, mechanical rooms, stair towers and elevator penthouse structures but excluding antennas, smokestacks, flag poles and other similar attachments.

NOTE: Authority cited: Section 142.3, Labor Code. Reference: Section 142.3, Labor Code.